



**DELHI JAL BOARD**  
( GOVT. OF N.C.T. DELHI )  
**QUALITY CONTROL LABORATORY,**  
**WATER TREATMENT PLANT NANGLOI , DELHI-110041**



International Year  
of Cooperatives  
*Cooperatives Build a Better World*

Water sample collected from "Mata Savitri Devi Sanjeevani Public School" K-32-38, Peepal Chowk, Mohan Garden, New Delhi -110059 vide challan No- 255 Dated - 18.02.2025.

S1: DJB stored water at above site

**THE TEST REPORT IS  
FOR THIS PARTICULAR  
WATER SAMPLE ONLY**

S2: Drinking Point at above site

S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	28.02.2025	28.02.2025
2.	Date of Analysis	-----	--	--	05.03.2025	05.03.2025
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	3.4	1.6
6.	PH value	-----	6.5	8.5	7.70	7.68
7.	Electrical Conductivity	µmho/cm	--	--	360.4	343.2
8.	Total dissolved solids	mg/l	500	2000	234.3	223.1
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	96	94
11.	Total Hardness	mg/l	200	600	138	134
12.	Calcium Hardness	mg/l	--	--	80	80
13.	Magnesium Hardness	mg/l	--	--	58	54
14.	Calcium as Ca	mg/l	75	200	32.0	32.0
15.	Magnesium as Mg	mg/l	30	100	13.92	12.96
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as No <sub>3</sub>	mg/l	45	N.R.	3.0	2.4
19.	Sulphate	mg/l	200	400	42	38
20.	Chloride	mg/l	250	1000	16	18
21.	Dissolved Iron	mg/l	1	N.R.	0.08	0.06
22.	Fluoride	mg/l	1	1.5	0.28	0.30
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	0.40	0.20
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0

REMARKS: As per tested parameters, Samples S-1 & S-2 can be used for drinking purpose.

ACWAIR Analyst

JAL BOARD

N.C.T. Delhi

Quality Control Laboratory

Nangloi, Delhi-41

Chairman

Mata Savitri Devi Sanjeevani Public School  
K-32-38, Peepal Chowk, Mohan Garden,  
New Delhi-110059

BACT.

Principal

Mata Savitri Devi Sanjeevani Public School  
K-32-38, Peepal Chowk, Mohan Garden,  
New Delhi-110059

A/CHEMIST





**MUNICIPAL CORPORATION OF DELHI**  
**PUBLIC HEALTH DEPARTMENT, WEST ZONE**  
**DR. SAHIB SINGH VERMA NIGAM BHAWAN**  
**SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027**



No.DHO/WZ/2025/D 808

Dated: 17/06/25

**HEALTH CERTIFICATE**

The school premises was inspected by officials of the Public Health Department in the presence of school management, and found to be in sanitary and hygienic condition from a health point of view. The details are as follow:

Name of the school: **M/s Sanjeevani Public School**

Address of School: **K-32-38 Peepal Chowk Mohan Garden New Delhi-110059, Shifts:**

ONE Timing: **MORNING**


No. of Students:              Boys: 318              Girls: 258      Total:- 576


No. of Staff (Teachers): Female: 34              Male: 10      Total: 44


That the accommodation provided for the class rooms as calculated.

- |    |  |           |
|----|--|-----------|
| 1. | (A) On floor space is sufficient   | Yes       |
|    | (B) On Cubic space is sufficient   | Yes       |
| 2. | That the classrooms are well ventilated                                      | Yes       |
| 3. | That the classrooms are kept neat and clean                                  | Yes       |
| 4. | That the classrooms are well lighted   | Yes       |
| 5. | That the drinking water is wholesome   | Wholesome |
| 6. | That the latrines arrangement is adequate and there are sufficient latrines. |           |
| 7. | That urinals arrangement is adequate and there are sufficient urinals        |           |

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school premises. This certificate has no bearing structure stability/ unauthorized construction and fire safety. This certificate is valid for one year from the date of issue.

  
**Dy. Health Officer**  
West Zone  
Dy Health Officer  
West Zone  
MCD

  
Chairman  
Mata Savitri Devi Sanjeevani Public School  
K-32-38, Peepal Chowk, Mohan Garden,  
New Delhi-110059

  
Principal  
Mata Savitri Devi Sanjeevani Public School  
K-32-38, Peepal Chowk, Mohan Garden,  
New Delhi-110059